



ASSAM PETRO-CHEMICALS LIMITED

(A Government of Assam Undertaking) | An ISO 9001:2008 Certified Company
CIN- U24116AS1971SGC001339, GSTN: 18AABCA6913A1Z6

Head Office & Factory Site:

Assam Petro-chemicals Ltd., Namrup, P.O. Parbatpur,
District: Dibrugarh, Assam-786623
Phone: (0374) 2500331/2500246/2500518, Fax: (0374) 2500231
Email: nrpapl@sancharnet.in, admin_apl@assampetrochemicals.co.in

Ref No: APL/Proj/Formalin-II/2019/3531

Date: 03/12/2019

Corrigendum - 5

Name of Work: Transshipment facility works of APL at Boitamari, Assam

Tender Number: TCE.6842A-CV-3000-3004 dated 16th October, 2019

The modification/ additional information of the above mentioned Tender document is attached here.

Sl. No.	Location	Stated in NIT and subsequent Corrigendum	Statement to be read as
1.	Volume-I, Section-A, Cl. No. 1.6.3 (V) (f) – Fire Protection System (Sheet 8 of 17) [NIT Page no.- 38 of 2047]	Pressure Switches shall be provided in the discharge line of the deluge valve & wet detection line. In case of fire & spray system activation the signal shall be sent to Fire Alarm Panel of the proposed facility.	Deluge Valve shall be provided with wet & electrical trim along with deluge valve local control panel for each system. The Pressure switches (on detection line & spray discharge line)& solenoid valve need to be connected(through deluge valve local control panel) to central Fire Protection Panel of the main facility located at adjacent Formaldehyde plant, from where “Fire”, “Spray ON” indication can be monitored, and remote actuation will be possible. Cabling between deluge valve local control panel and Fire Protection Panel of the main facility located at adjacent Formaldehyde plant will be in the scope of transshipment contractor. Deluge Valve shall be housed in a DV housing constructed by masonry brick wall with a roof made of corrugated sheet.

Sd/-
Managing Director